



Sanitary Sewer Overflow Annual Report Division of Surface Water

Date: 03/06/2017

Facility Name: Newark WWTP

Ohio NPDES Permit Number: 4PE00001*MD

Period Covered by Report: 01/01/2016 - 12/31/2016

Contact Person

Name: Darin Wise

Title: Wastewater Plant Superintendent

Mailing Address: 1003 East Main Street

City: Newark

State: OH

Zip Code: 43055

Country: USA

Sanitary Sewer Overflows Spreadsheet(attachment) :

Water In Basement Occurrences Spreadsheet(attachment) : *Copy of WIBOccurrences 2016 (002).xlsm*

Narrative analysis of WIB patterns by location, frequency and cause: *Many of the plugs found in the City sewer mains are tree root related, some of the plugs are due to grease and detergent.*

There is no set pattern in these areas, after a plug we televise the affected area and try to determine what may have caused the problem.

Additional Attachments :

Certification	
<i>I certify under penalty of law that I have personally examined and am familiar with the information in this report and all attachments. Based on my inquiry of those persons immediately responsible for obtaining the information contained in the report, I believe that the information is true, accurate, and complete.</i>	
Name: Darin E Wise	Title: Plant Superintendent
Signature(Electronically submitted by): Darin E Wise (User ID: dwise)	Submission Date: 03/06/2017

