

Division of Surface Water

Sanitary Sewer Overflow Annual Report

Report ID: 3021998

General Information		
Report Date: 02/08/2019		
POTW: Newark WWTP		
Ohio NPDES Permit Number: 4PE00001*MD		
Period Covered by Report	From: 01/01/2018	To: 12/31/2018
Contact Person	First Name: Bryan	Last Name: Curry
Contact Person Title: Wastewater Facilities Manager		
Email: bcurry@newarkohio.net		
Contact Phone: 7403496769		
Mailing Address: 1003 E. Main St.		
City: Newark	State: OH	Zip Code: 43055
Address Country: USA		

Sanitary Sewer Overflow
Have any Sanitary Sewer Overflows occurred during the reporting period? No
Sanitary Sewer Overflows Spreadsheet:

Water In Basement Occurrences
Were there any Water In Basement Occurrences during the reporting period? Yes
Water In Basement Occurrences Spreadsheet: WIBOccurrences2018.xlsm
Enter narrative analysis of WIB patterns by location, frequency and cause: There were only three occurrences during 2018 and two were caused by roots and the third was from grease. The grease blockage was not in an area where there are restaurants, must be accumulation from households.

Additional Information
Additional Attachments: